



SAFE STAKES FIRE SAFETY SERVICES

AN ISO 9001 : 2015 CERTIFIED COMPANY

Approved By Government of Maharashtra License Agency
Fire Extinguisher Fire Hydrant System Fire Detection System

Ref:SSFSS/2024/D71

With reference cited above , below are the details of fire fighting system at : -

TO,

Hon. Shri Annasaheb Dange Ayurved Medical Collage
Dhanvantari Hospital Ashta

Annexure For Form B

Type of Appliances	Capacity	Qty.	Re lling	Servicing	H.P Tes ng	Remarks
ABC	06 Kg	05	Yes	Yes	Yes	Yes-ok
Co2	02 kg	01	Yes	Yes	Yes	Yes-ok
Co2	4.5Kg	04	Yes	Yes	Yes	Yes-ok

The above said fire Protection equipment installed in good working condition. There after any alteration in above system by occupant or developer will make this certificate invalid

Thanking you

Period:- 1st July2023 To 31st DECEMBER 2023

Issus Date :- 02.04.2024

Place:- Mumbai

License No:- MFS-LA-RF-39

License No:- MFS-LA-RF-38



Aspen
PRINCIPAL

Shri Annasaheb Dange Ayurved Medical
Collage Ashta Tal. Wahva Dist. Sangli

ARKAM

Digitally Signed

by ARKAM

Date : 2024.04.02

13:11:21 +05'30

Signatories

Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai - 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in

FORM N
[(See section 9 (3) and rule 14)
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / RF-39 / RD- 38

Date: 13.01.2024

License is hereby granted under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Safe Stakes Fire Safety Services** having their registered office at **Ekta Nagar, Hill No. 04, Ghatkopar (W), Mumbai 400086** and their contact details are Office Number: 9833939623 and Email ID: safestakes92@gmail.com with PAN registration No. CNKPA8363B and GST No. 27CNKPA8363B1Z4 to act as a Licensed Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to *Hon. Shri Annesahab Dange Ayurved Medical College & Dhankantari Hospital Ashta*

1. Fire Fighting and Sprinkler System: Class D
2. Detection and Fire Suppression System: Class D

M/s. Safe Stakes Fire Safety Services shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **13.01.2024 to 12.01.2026**

Hatyal
Kiran
Asst Director

Digitally signed
by **ARKAM**
Date: 2024.01.15
22:14:05 +05'30'

Santosh
Shridhar
Warick
(S S Warick)
Director
Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B


Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.



Asst. Dir.
PRINCIPAL

Shri Annesahab Dange Ayurved Medical
College, Ashta, Tal. Walwa, Dist. Sangli



श्रीनिवास फायर सर्विसेस

सेल्स अँड सर्विसेस

सर्व प्रकारची अग्नीशामक उपकरणे व सेफ्टी स्प्रेन्नर पार्ट्स विक्री व दुरुस्ती.

संगली जिल्हा आयुर्विद्येक व योगसंश्लेषक अभ्यासगण, संगली - (ऑ.) २०२४६४००९ / २०२३३९२६३०

श्रीनिवास फायर सर्विसेस

हरिपूर रोड, पुलाजवळ

सांगली - ४१६ ४१६.

फोन : (ऑ.) २०२४६४००९

२०२३३९२६३०

Ref no-SNFFE/ 180123110

TEST CERTIFICATE

हरिपूर रोड, पुलाजवळ

सांगली - ४१६ ४१६.

फोन : (ऑ.) २०२४६४००९

२०२३३९२६३०

16/01/2024

Date : 16/01/2024

To,
Hoh. Shri. Anhasheb
Dange Bhanvandra
Hospital.

At Post. Astha Tal. Walwa

Dis. Sangli

As per instructions laid Down in IS 2190 - 1992 (Code of Proactive for Selection and maintenance of Portable First Aid Fire Appliance), We have Carried out the job in your premises as under :-

Sr. No	Types of Appliances	Capacity	No.	Refilling	Servicing	HP Testing	Remarks
1	ABC type fire extinguishers	06 Kg	05	✓	✓	+	OK
2	ABC type fire extinguishers	- Kg	-	✓	✓	✓	OK
3	BC type fire extinguishers	- Kg	-	✓	✓	✓	OK
4	Co2 type fire extinguishers	02 Kg	01	✓	✓	+	OK
5	Co2 type fire extinguishers	4.5 Kg	04	✓	✓	+	OK

The above Fire extinguishers are maintained by us as per Indian standard Code IS : 2190 of practice and they are now in perfect working conditi

TO WHOMSOEVER IT MAY CONCERN


We Shrinivas Fire Services, Sangli Dist. Sales and Services of Fire Fighting Equipments certify that the below mentioned/New Supply Fire Extinguishers of...Have been serviced & refilled by us :-

Sr. No.	Types of Appliances	Capacity	Nos	Remark
1	ABC type fire extinguishers	06 Kg	05	OK
2	ABC type fire extinguishers	- Kg	-	OK
3	BC type fire extinguishers	- Kg	-	OK
4	Co2 type fire extinguishers	02 Kg	01	OK
5	Co2 type fire extinguishers	4.5 Kg	04	OK

The Above Fire Extinguishers are in Good Working Condition
Next Servicing Due Date :- 15 / 01 / 2025


15/01/2025

श्रीनिवास फायर सर्विसेस
For SHRINIVAS FIRE SERVICES
प्रोप्रायटर/मनेजर



Aspen
PRINCIPAL

Shri Anhasheb Dange Ayurved Medical
College, Astha Tal. Walwa Dist. Sangli



श्रीनिवास फायर सर्विसेस

सेल्स अँड सर्विसेस

सर्व प्रकारची अग्निशामक उपकरणे व सेफ्टी रियेजर्स पारटेस, मिरिन् व दुकती.

श्रीनिवास फायर सर्विसेस

हरिपूर रोड, पुलाजवळ

सांगली - ४१६ ४१६.

फोन : (आ.) २०२४४४६०९

२०२३३९०६३०

Ref no-SNFFE/ 180123/10 **TEST CERTIFICATE**

श्रीनिवास फायर सर्विसेस

हरिपूर रोड, पुलाजवळ

सांगली - ४१६ ४१६.

फोन : (आ.) २०२४४४६०९

२०२३३९०६३०

Date : 16/01/2024

16/01/2024

To, Hob shri Anneshab
Dange Ayurved Medicines
Ashta

At Post. Ashta

Tal. Wakwa

Dis. Sangli

As per instructions laid Down in IS 2190 - 1992 (Code of Proactive for Selection and maintenance of Portable First Aid Fire Appliance), We have Carried out the job in your premises as under :-

Sr. No	Types of Appliances	Capacity	No.	Refilling	Servicing	HP Testing	Remarks
(1)	ABC type fire extinguishers	06 Kg	08	✓	✓	✓	OK
2)	ABC type fire extinguishers	- Kg	-	✓	✓	✓	OK
3)	BC type fire extinguishers	- Kg	-	✓	✓	✓	OK
(4)	Co2 type fire extinguishers	02 Kg	02	✓	✓	✓	OK
(5)	Co2 type fire extinguishers	4.5 Kg	06	✓	✓	✓	OK

The above Fire extinguishers are maintained by us as per Indian standard Code IS : 2190 of practice and they are now in perfect working conditi

TO WHOMSOEVER IT MAY CONCERN

We Shrinivas Fire Services, Sangli Dist. Sales and Services of Fire Fighting Equipments certify that the below mentioned/New Supply Fire Extinguishers of...Have been serviced & refilled by us :-

Sr. No.	Types of Appliances	Capacity	Nos	Remark
(1)	ABC type fire extinguishers	06 Kg	08	OK
2)	ABC type fire extinguishers	- Kg	-	OK
3)	BC type fire extinguishers	- Kg	-	OK
(4)	Co2 type fire extinguishers	02 Kg	02	OK
(5)	Co2 type fire extinguishers	4.5 Kg	06	OK

The Above Fire Extinguishers are in Good Working Condition
Next Servicing Due Date :- 15/01/2025



Ashta
PRINCIPAL

For SHRINIVAS FIRE SERVICES
पोप्रायटर/मॅनेजर

Shri Anneshab Dange Ayurved Medical
College, Ashta, Tal. Wakwa, Dist. Sangli



KOLHAPUR MUNICIPAL CORPORATION



Out No.MFS/KMC/26/2022

Tel No.0231 -2540291 to 97

Kolhapur Fire and Emergency Service

main building, Bhausingji road

Kolhapur - 416002 .

Date - 05/10/2023

To,
Dhanvantari Hospital,
Sant Dyananeshwar Shikshan Sanstan,
Gat No. 607/1 & 607/3 At. Post Ashta,
Tal- Walwa, dist- Sangli

Sub: Grant "Final No Objection Certificate" for your Building for Dhanvantari Hospital, Sant Dyananeshwar Shikshan Sanstan, Gat No. 607/1 & 607/3 At. Post Ashta, Tal- Walwa, dist- Sangli

Ref: 1 Certificate Submitted by Licence Agency- Safe House Fire Engineering Services. MFS-LA/RF-146/RD-137/RP-29 Dated-04/10/2023.

2. Your Letter Dated 04/10/2023


This has reference to the above. This office has NO Objection for (Final) Fire Approval for following Occupancy -

Proposed Built up area is **6597.25 Sq Mtrs** . Since the fire fighting arrangements provided is installed by License Agency i.e. **Safe House Fire Engineering Services. MFS-LA/RF-146/RD-137/RP-29 Dated-04/10/2023** issued by Directorate of Maharashtra Fire Service and has submitted Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Final No-Objection Certificate" for your following building having built up area admeasuring to **6597.25 Sq Mtrs**. And high is 15.15 mitres. The detail of the proposed Construction is as under,

Sr. No.	Floor	Built Up Area In Sq. Mtrs
02.	Ground Floor	2052.95 Sq. Mtrs
03	1 st Floor	1984.82 Sq. Mtrs
04	2 nd Floor	1551.67 Sq. Mtrs
05	3 rd Floor	1007.81 Sq. Mtrs
Total Built up area in Sq. Mtrs.		6597.25 Sq. Mtrs

Statutory Provisions Under Maharashtra Fire Prevention and Life Safety Measures Act, 2006

- Under **Section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" (hereinafter referred to as "said Act"). The applicant (developer, owner, occupier by whatever name called) shall comply with all the Fire and Life Safety measures adhering to National Building Code of India, 2005 and as amended from time to time failing which it shall be treated as a violation of the said Act.
- It is presumed that you have completed the work adhering to the provisions under **section-3** of the said Act.
- Under **sub-section (3) of Section 3**, it is responsibility of the Owner or the Occupier as the case maybe, shall furnish to The Chief Fire Officer or nominated officer o Certificate in a



Ananashab Dange
PRINCIPAL

Shri Ananashab Dange Ayurved Medical
College, Ashta, Tal. Walwa, Dist. Sangli

prescribed form twice a year in the month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

04. Under sub section (4) of section 3, no person shall tamper with, alter, remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any other person to do so.

The Fire Fighting System provided by you in the premises as per Provisional No-Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The condition mentioned in "Provisional No-Objection Certificate" will remain unchanged. The undersigned reserves right to amend any additional recommendation deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. If any change of Activity or Transfer of Plot or any future expansion, No-Objection Certificate from this office is essential.

As per Maharashtra Fire Prevention and Life Safety Measures Act, 2006, Section 25-Annexure-Part III of Dhanvantari Hospital, Sant Dyananeshwar Shikshan Sanstan, Gat No. 607/1 & 607/3 At. Post Ashta, Tal- Walwa, dist- Sangli .has paid Fire Protection Fund Fees amount to Rs. 39,583/- (Rs. Thirty Nine Thousand Five Hundred And Eighty Three Only Only) vide UTR NO. ibkl230603748609, Dated 03/06/2023.

Copy submitted to:

01. The Concern Planning Authority for information.

MANISH
PRAFUL
RANBHISE

Chief Fire Officer

Kolhapur Municipal Corporation

Digitally signed by MANISH PRAFUL RANBHISE
DN: c=IN, o=PERSONAL, title=8838, pseudonym=aa0fb2ca69e2453f8b1da1cfda733b98,
2.5.4.20=347da94af85923cece64a7a2a49910ae7db20cda5620cbd117ced9f56fcd70, postalCode=416003,
st=Maharashtra,
serialNumber=626e0303437902ca945e65fe970ffe81466b5b6fa6c86a60fea3a36bb0efef8, cn=MANISH PRAFUL RANBHISE
Date: 2023.10.05 18:32:51 +05'30'



Ashta
PRINCIPAL
Shri Annesohab Dange Ayurved Medical
College, Ashta, Tal. Walwa, Dist. Sangli



SAFE STAKES FIRE SAFETY SERVICES

AN ISO 9001 : 2015 CERTIFIED COMPANY

Approved By Government of Maharashtra License Agency
Fire Extinguisher Fire Hydrant System Fire Detection System

Ref:SSFSS/2024/D71

FORM B

(See Section 3(3) and Rule 4(2))

Six Monthly Certificates to be given in every January to June and July to December by the owner or the occupier for Compliance of Fire prevention and life safety measures.

CERTIFICATE

Certified that I/We have carried out inspection of the fire prevention and life safety measures Installed in the following building or premises, namely:-

TO,

Hon. Shri Annasaheb Dange Ayurved Medical Collage
Dhanvantari Hospital Ashta

I/We Further certify that these installation in above mentioned buildings are maintained in good repair and efficient condition during the period 01 July 2023 To 31 December 2023 as required under the provision of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah.III of 2007) The details of installations carried out by/us are mentioned in the report appended here with.


Period:- 1st July 2023 To 31st DECEMBER 2023

Issus Date :- 02.04.2024

Place:- Mumbai

License No:- MFS-LA-RF-39

License No:- MFS-LA-RF-38



ARKAM
PRINCIPAL

Shri Annasaheb Dange Ayurved Medical
College, Ashta, Tal. Walwa, Dist. Sangli

ARKAM

Signatories

Digitally Signed
by ARKAM
Date : 2024.04.02
15:09:10 +05'30


Reg Office : Ekta Nagar Near Shah Lime Depot, Hill No. 4, Opp. Glass Factory, Ghatkopar West, Mumbai - 400086.

Work : 1st floor Malwa compound. L.b.s road naryan nagar near Mahindra park ghatkopar west mumbai 400086.

Contact No. +91 7208128824 / 7208128854 Email Id.: safestakes92@gmail.com

TAX INVOICE

(ORIGINAL FOR RECIPIENT)

 <p>Pest Relief (India) Pvt. Ltd-Pune OFFICE NO:30, 5th FLOOR, A-WING, SILVAR SPACE BLDG, ABOVE MORE STORE, VISHAL NAGAR, PIMPLE NILAKH, PUNE-411027 MOBILE NO.: 7498466005 GSTIN/UIN: 27AAGCP4761N1ZU State Name : Maharashtra, Code : 27 E-Mail : pune@pestreliefindia.com</p>	Invoice No. PRI/P/0743/20-21	Dated 6-Mar-2021
	Delivery Note	Mode/Terms of Payment
<p>Consignee Annasaheb Dange Ayurved Medical College Dhanwanti Hospital A/p- Ashta, Tal- Walwa, Dist- Sangli- 416301 State Name : Maharashtra, Code : 27</p> <p>Buyer (if other than consignee) Annasaheb Dange Ayurved Medical College Dhanwanti Hospital A/p- Ashta, Tal- Walwa, Dist- Sangli- 416301 State Name : Maharashtra, Code : 27</p>	Supplier's Ref. PRI/P/0743/20-21	Other Reference(s)
	Buyer's Order No.	Dated
	Despatch Document No.	Delivery Note Date
	Despatched through	Destination
Terms of Delivery		

SI No.	Description of Services	HSN/SAC	Quantity	Rate	per	Amount
1	Commercial Pest Management Service (Ser) Date - 05 Mar 2021 (Cleaning Services)	998539	1 Service	2,118.64	Service	2,118.64
						SGST 190.68
						CGST 190.68
Total			1 Service			₹ 2,500.00


Amount Chargeable (in words) **INR Two Thousand Five Hundred Only** E. & O.E


HSN/SAC	Taxable Value	Central Tax		State Tax		Total Tax Amount
		Rate	Amount	Rate	Amount	
998539	2,118.64	9%	190.68	9%	190.68	381.36
Total	2,118.64		190.68		190.68	381.36

Tax Amount (in words) : **INR Three Hundred Eighty One and Thirty Six paise Only**


Company's Bank Details
Bank Name : **State Bank of India A/c No - 61321968359**
A/c No. : **61321968359**
Branch & IFS Code : **SBIN0016542**

Declaration
"I/We declare that this invoice shows the actual price of the goods & service described that all particulars are true and correct."

for Pest Relief (India) Pvt. Ltd-Pune

Authorised Signatory



This is a Computer Generated Invoice


PRINCIPAL
Shri Annasaheb Dange Ayurved Medical College, Ashta, Tal. Walwa, Dist. Sangli

SHRINIVAS FIRE SERVICES**Sales Corporation**

Fire Fighting Equipments, Maintenance Contractors

Office : Near Bridge, Haripur Road, (Rajmati Colony) Bhag No. 2, SANGLI. 416 416
Ph. 9923312630, Mob.: 8459299770

Sales & Service of All Types - Fire Extinguishers, Fire Hose Pipes, Hose Fittings & Entire Range of Fire Fighting Equipments & Mill Gin & Hydrant.

Ref. No. : SNFFE / 180123/01 **TEST CERTIFICATE** Date : 21/01/2023

To,

Hon. Shri. Annasaheb Dange
Ayurved Medical college,
Dhanvantari Hospital, Ashta.

At Post. Ashta

Tal. Walwa

Dis. Sangli

As per instructions laid Down in IS 2190 - 1992 (Code of Proactive for Selection and maintenance of Portable First Aid Fire Appliance), We have Carried out the job in your premises as under :-

Sr. No	Types of Appliances	Capacity	No.	Refilling	Servicing	HP Testing	Remarks
1)	BC type fire extinguishers			✓	✓	✓	OK
(2)	ABC type fire extinguishers	06 kg	04	✓	✓	✓	OK
3)	ABC type fire extinguishers			✓	✓	✓	OK
(4)	Co2 type fire extinguishers	02 kg	01	✓	✓	✓	OK
(5)	Co2 type fire extinguishers	405 kg	01	✓	✓	✓	OK

The above Fire extinguishers are maintained by us as per Indian standard Code IS : 2190 of practice and they are now in perfect working conditi

TO WHOMSOEVER IT MAY CONCERN


We Shrinivas Fire Services, Sangli Dist. Sales and Services of Fire Fighting Equipments certify that the below mentioned/New Supply Fire Extinguishers of...Have been serviced & refilled by us :-

Sr. No.	Types of Appliances	Capacity	Nos	Remark
1)	BC type fire extinguishers			OK
(2)	ABC type fire extinguishers	06 kg	04	OK
3)	ABC type fire extinguishers			OK
(4)	Co2 type fire extinguishers	02 kg	01	OK
(5)	Co2 type fire extinguishers	405 kg	01	OK

The Above Fire Extinguishers are in Good Working Condition

Next Servicing Due Date :- 20/01/2024

For SHRINIVAS FIRE SERVICES



PRINCIPAL

Shri Annasaheb Dange Ayurved Medical
College, Ashta, Tal. Walwa, Dist. Sangli

श्रीनिवास फायर सर्व्हिसेस करित

प्राप्रायटर/मॅनेजर

SHRINIVAS FIRE SERVICES

Sales Corporation

Fire Fighting Equipments, Maintenance Contractors

Office : Near Bridge, Haripur Road, (Rajmati Colony) Bhag No. 2, SANGLI 416 416
Ph. 9923312630, Mob. 8459299770

Sales & Service of All Types - Fire Extinguishers, Fire Hose Pipes, Hose Fittings & Entire Range of Fire Fighting Equipments & Mill Gin & Hydrant.

Ref. No. : SNFFE / 18012101 **TEST CERTIFICATE** Date: 21/01/2023

To,

Hon. Shri. Anasaheb Dange
Ayurved Medical College
Ashta



At Post. Ashta

Tal. Wakwa

Dis. Sangli

As per instructions laid Down in IS 2190 - 1992 (Code of Proactive for Selection and maintenance of Portable First Aid Fire Appliance), We have Carried out the job in your premises as under :-

Sr. No	Types of Appliances	Capacity	No.	Refilling	Servicing	HP Testing	Remarks
1)	BC type fire extinguishers			√	√	√	OK
2)	ABC type fire extinguishers			√	√	√	OK
3)	ABC type fire extinguishers	06kg	09	√	√	√	OK
4)	Co2 type fire extinguishers	02kg	03	√	√	√	OK
5)	Co2 type fire extinguishers	405kg	08	√	√	√	OK

The above Fire extinguishers are maintained by us as per Indian standard Code IS : 2190 of practice and they are now in perfect working condition

TO WHOMSOEVER IT MAY CONCERN

We Shrinivas Fire Services, Sangli Dist. Sales and Services of Fire Fighting Equipments certify that the below mentioned/New Supply Fire Extinguishers of...Have been serviced & refilled by us :-

Sr. No.	Types of Appliances	Capacity	Nos	Remark
1)	BC type fire extinguishers			OK
2)	ABC type fire extinguishers			OK
3)	ABC type fire extinguishers	06kg	09	OK
4)	Co2 type fire extinguishers	02kg	03	OK
5)	Co2 type fire extinguishers	405kg	08	OK

The Above Fire Extinguishers are in Good Working Condition

Next Servicing Due Date :- 20/01/2024

For SHRINIVAS FIRE SERVICES

श्रीनिवास फायर सर्विसेस करित



PRINCIPAL

Shri Anasaheb Dange Ayurved Medical College, Ashta, Tal. Wakwa, Dist. Sangli

Signature
प्राप्रायटर/मनेजर

४५ वर्षांची अखंड सेवा

SHRINIVAS FIRE SERVICES

← Sales Corporation ←

Fire Fighting Equipments, Maintenance Contractors

Office : Near Bridge, Haripur Road, (Rajmati Colony) Bhag No. 2, SANGLI. 416 416

Ph. 9923312630, Mob.: 8459299770

Sales & Service of All Types - Fire Extinguishers, Fire Hose Pipes, Hose Fittings & Entire Range of Fire Fighting Equipments & Mill Gin & Hydrant.

ट्रेनिंग प्रमाणपत्र

Ref. No. : SNFFE / 180123101

Date : 21/01/2023

Date: -२१.०१.२०२३

प्रति,

Hon. Shri Annasaheb Dange

Ayurved Medical College,

Dhanvantari Hospital Ashta



विषय :- आपले हॉस्पिटल मधील डॉक्टर व ऑफिस स्टाफ यांना अग्निशमन उपकरणांचे ट्रेनिंग दिले बाबत.

महोदय,

वरील उपरोक्त विषयास अनुसरून आम्ही असे प्रमाणित करित आहोत की, आपले Hon. Shri Annasaheb Dange Ayurved Medical College, Dhanvantari Hospital Ashta या ठिकाणी बसविणेत आलेल्या आग प्रतिबंधक व जिवसंरक्षण उपाययोजनांच्या फायर उपकरणांची तपासणी केलेली आहे.

आम्ही प्रमाणीत करतो की, महाराष्ट्र आग प्रतिबंधक व जीवसंरक्षक उपाययोजना अधिनियमा प्रमाणे दि. ०१ जानेवारी २०२३ ते ३१ डिसेंबर २०२३ पर्यंत या कालावधी करीता वर नमुद केलेल्या इमारतीमधील बसविणेत आलेले आहेत. ते सर्व अग्निशमण उपकरणे सर्व ऑफिस स्टॉप व आपले फर्म मधील सर्व कामगारांना अग्निशमण उपकरणांचे प्रात्यक्षित दाखवून ते कासे वपरावायचे व त्याची काळजी कशी घ्यावयाची याची सर्व माहिती दिलेली आहे.



PRINCIPAL

Shri Annasaheb Dange Ayurved Medical College, Ashta, Tal. Waiwada, Dist. Sangli



आपला विश्वासु

श्रीनिवास फायर सर्व्हिसेस

श्रीनिवास फायर सर्व्हिसेस कारंता

21/01/2023

प्रोप्रायटर / मॅनेजर

Abhishek A. Chapekar

SHRINIVAS FIRE SERVICES

४५ वर्षांची अखंड सेवा

Sales Corporation

Fire Fighting Equipments, Maintenance Contractors

Office : Near Bridge, Haripur Road, (Rajmati Colony) Bhag No. 2, SANGLI. 416 416
Ph. 9923312630, Mob.: 8459299770

Sales & Service of All Types - Fire Extinguishers, Fire Hose Pipes, Hose Fittings & Entire Range of Fire Fighting Equipments & Mill Gin & Hydrant.

Ref. No. : SNFFE /

Date : 15/1/2022

TEST CERTIFICATE

Ref no-SNFFE/180/1001/21-22

15/01/2022

To,
Hou. Shri Annasaheb Dange
Dhanvantri Hospital Ashta



At Post. Ashta

Tal. Walwa

Dis. Sangli

As per instructions laid Down in IS 2179 - 1990 (Code of Proactive for Selection and maintenance of Portable First Aid Fire Appliance), We have Carried out the job in your premises as under :-

Sr. No	Types of Appliances	Capacity	Nos.	Refilling	Servicing	Testing	Remarks
1)	Dry powder ABC stored pressure type fire extinguishers	6 kg	05	√	√	√	OK
2)	Co2 type fire extinguishers	2 kg	01	√	√	√	OK
3)	Co2 type fire extinguishers	4.5 kg	04	√	√	√	OK

The above Fire extinguishers are maintained by us as per Indian standard Code IS : 2190 of practice and they are now in perfect working condition

TO WHOMSOEVER IT MAY CONCERN

We Shrinivas Fire Services, Sangli Dist. Sales and Services of Fire Fighting Equipments certify that the below mentioned/New Supply Fire Extinguishers of... Have been serviced & refilled by us :-

Sr. No.	Types of Appliances	Nos	Remark
1)	Dry powder ABC stored pressure type fire extinguishers 6Kg capacity	05	OK
2)	Co2 type fire extinguishers 2 Kg capacity	01	OK
3)	Co2 type fire extinguishers 4.5 Kg capacity	04	OK

The Above Fire Extinguishers are in Good Working Condition
Next Servicing Due Date :- 14 / 01 / 2023



Aspen
PRINCIPAL

Shri Annasaheb Dange Ayurved Medical
College, Ashta, Tal. Walwa, Dist. Sangli

For SHRINIVAS FIRE SERVICES

श्रीनिवास फायर सर्विसेस करिता
Shrinivas
15/1/22
प्रमाणित/मॅनेजर

४५ वर्षांची अखंड सेवा

SHRINIVAS FIRE SERVICES

→ Sales Corporation ←

Fire Fighting Equipments, Maintenance Contractors

Office : Near Bridge, Haripur Road, (Rajmati Colony) Bhag No. 2, SANGLI. 416 416
Ph. 9923312630, Mob.: 8459299770

Sales & Service of All Types - Fire Extinguishers, Fire Hose Pipes, Hose Fittings & Entire Range of
Fire Fighting Equipments & Mill Gin & Hydrant.

Ref. No. : SNFFE /

Date : 15/01/2022

TEST CERTIFICATE

Ref no-SNFFE/180/1002/21-22

15/01/2022

To,
Hou. Shri Annasaheb Dange
Ayurved Medical College Ashta



At Post. Ashta

Tal. Walwa

Dis. Sangli

As per instructions laid Down in IS 2179 - 1990 (Code of Proactive for Selection and maintenance of Portable First Aid Fire Appliance), We have Carried out the job in your premises as under :-

Sr. No	Types of Appliances	Capacity	Nos.	Refilling	Servicing	Testing	Remarks
1)	Dry powder ABC stored pressure type fire extinguishers	6 kg	08	√	√	√	OK
2)	Co2 type fire extinguishers	2 kg	02	√	√	√	OK
3)	Co2 type fire extinguishers	4.5 kg	06	√	√	√	OK


The above Fire extinguishers are maintained by us as per Indian standard Code IS : 2190 of practice and they are now in perfect working conditi

TO WHOMSOEVER IT MAY CONCERN

We Shrinivas Fire Services, Sangli Dist. Sales and Services of Fire Fighting Equipments certify that the below mentioned/New Supply Fire Extinguishers of...Have been serviced & refilled by us :-

Sr. No.	Types of Appliances	Nos	Remark
1)	Dry powder ABC stored pressure type fire extinguishers 6Kg capacity	08	OK
2)	Co2 type fire extinguishers 2 Kg capacity	02	OK
3)	Co2 type fire extinguishers 4.5 Kg capacity	06	OK

The Above Fire Extinguishers are in Good Working Condition
Next Servicing Due Date :- 14/01/2023



PRINCIPAL

Shri Annasaheb Dange Ayurved Medical
College, Ashta, Tal. Walwa, Dist. Sangli

For SHRINIVAS FIRE SERVICES

श्रीनिवास कायदा सन्विसेस करिता
ShriWaj101

४५ वर्षाची अखंड सेवा

SHRINIVAS FIRE SERVICES

Sales Corporation

Fire Fighting Equipments, Maintenance Contractors

Office : Near Bridge, Haripur Road, (Rajmati Colony) Bhag No. 2, SANGLI. 416 416
Ph. 9923312630, Mob.: 8459299770

Sales & Service of All Types - Fire Extinguishers, Fire Hose Pipes, Hose Fittings & Entire Range of Fire Fighting Equipmnts & Mill Gin & Hydrand.

Ref. No. : SNFFE /

Date :

Ref no-SNFFE/180/12/20

TEST CERTIFICATE

Date :17/12/2020

To,
Hon. Shri . Annasaheb Dange
Dhanvantri Hospital , Astha

At Post. Astha, Tal.Valwa Dis. Sangli

As per instructions laid Down in IS 2190 - 1992 (Code of Proactive for Selection and maintenance of Portable First Aid Fire Appliance), We have Carried out the job in your premises as under :-

Sr. No	Types of Appliances	Capacity	No.	Refilling	Servicing	HP Testing	Remarks
1)	ABC type fire extinguishers	06 Kg	03	√	√	√	OK
2)	ABC type fire extinguishers	06 Kg	01	√	√	√	OK
3)	Co2 type fire extinguishers	02 Kg	01	√	√	√	OK
4)	Co2 type fire extinguishers	4.5 Kg	05	√	√	√	OK

The above Fire extinguishers are maintained by us as per Indian standard Code IS : 2190 of practice and they are now in perfect working Condit

TO WHOMSOEVER IT MAY CONCERN

We Shrinivas Fire Services, Sangli Dist. Sales and Services of Fire Fighting Equipments certify that the below mentioned/New Supply Fire Extinguishers of...Have been serviced & refilled by us :-

Sr. No.	Types of Appliances	Capacity	Nos	Remark
1)	ABC type fire extinguishers	06 Kg	03	OK
2)	ABC type fire extinguishers	06 Kg	01	OK
3)	Co2 type fire extinguishers	02 Kg	01	OK
4)	Co2 type fire extinguishers	4.5 Kg	05	OK

The Above Fire Extinguishers are in Good Working Condition

Next Servicing Due Date :- 15 / 12 / 2021

31/12/2021

For SHRINIVAS FIRE SERVICES

श्रीनिवास फायर सर्विसेस करिता

प्रोग्रायटर / मॅनेजर



Annasaheb
PRINCIPAL

श्री. Annasaheb Dange Ayurved Medical
College, Astha, Tal. Valwa, Dist. Sangli



SHRINIVAS FIRE SERVICES

४५ वर्षाची अखंड सेवा

Sales Corporation

Fire Fighting Equipments, Maintenance Contractors

Office : Near Bridge, Haripur Road, (Rajmati Colony) Bhag No. 2, SANGLI. 416 416
Ph. 9923312630, Mob.: 8459299770

Sales & Service of All Types - Fire Extinguishers, Fire Hose Pipes, Hose Fittings & Entire Range of Fire Fighting Equipments & Mill Gin & Hydrant.

Ref. No. : SNFFE /

Date :

Ref no-SNFFE/180/12/20

TEST CERTIFICATE

Date : 17/12/2020

To,
Hon. Shri . Annasaheb Dange
Dhanvantri Hospital , Astha

At Post. Astha, Tal.Valwa Dis. Sangli

As per instructions laid Down in IS 2190 - 1992 (Code of Proactive for Selection and maintenance of Portable First Aid Fire Appliance), We have Carried out the job in your premises as under :-

Sr. No	Types of Appliances	Capacity	No.	Refilling	Servicing	HP Testing	Remarks
1)	ABC type fire extinguishers	06 Kg	03	√	√	√	OK
2)	ABC type fire extinguishers	06Kg	01	√	√	√	OK
3)	Co2 type fire extinguishers	02 Kg	01	√	√	√	OK
4)	Co2 type fire extinguishers	4.5 Kg	05	√	√	√	OK

The above Fire extinguishers are maintained by us as per Indian standard Code IS : 2190 of practice and they are now in perfect working Condit

TO WHOMSOEVER IT MAY CONCERN

We Shrinivas Fire Services, Sangli Dist. Sales and Services of Fire Fighting Equipments certify that the below mentioned/New Supply Fire Extinguishers of...Have been serviced & refilled by us :-

Sr. No.	Types of Appliances	Capacity	Nos	Remark
1)	ABC type fire extinguishers	06 Kg	03	OK
2)	ABC type fire extinguishers	06Kg	01	OK
3)	Co2 type fire extinguishers	02 Kg	01	OK
4)	Co2 type fire extinguishers	4.5 Kg	05	OK

The Above Fire Extinguishers are in Good Working Condition

Next Servicing Due Date :- 15 / 12 / 2021

31/12/2021



PRINCIPAL

Shri Annasaheb Dange Ayurved Medical
College, Astha, Tal. Valwa, Dist. Sangli



For SHRINIVAS FIRE SERVICES

श्रीनिवास फायर सर्विसेस कार्यालय

प्रमाणित / मॅनेजर