



SAFE HOUSE FIRE ENGINEERING SERVICES

Maharashtra Fire Services Authorized Company

WE INSTALL AND SUPPLY ALL KINDS OF FIRE EQUIPMENTS

REGISTERED OFFICE : PLOT NO. 17,
ANNA SMRUTI, RAJPUT MALA,
ABHAYNAGAR, SANGLI - 416416.

+91 702 056 1080.
+91 830 875 6131.

CORPORATE OFFICE : SHOP NO. 1, P LOT NO. 27,
SECTOR 22, GANESH HOUSING SOCIETY,
KAMOTHE, NAVI MUMBAI 410209.

safehousefireservices@gmail.com
info@safehousefires.com

BRANCH OFFICE : OPPOSITE SAHYADRI HOTEL,
HADAPSAR-SASWAD ROAD URALI DEVANCHI,
TAL.-HAVELI, DIST-PUNE - 412308.

Web: www.safehousefires.com

REF. NO **SHFES/01/13**

DATE : **13/ 01/ 2025**

FORM B

[(See section 3(3) and rule 4(2))]

CERTIFICATE

Certified that I/We have Carried out inspection Of fire Prevention & Life Safety Measures
Installed In the following Building or Premises namely ,

To,
M/s. Dhanvantri Hospital,
Sant Dynaneshwar Shikshan Sanstan,
Gat No 607/1 & 607/ 3 at. Post Ashta,
Tal - Walwa, Dist - Sangli .

We further certify that these installation in the below mentioned buildings
are maintained in good repair and efficient conditions during the period **Jul 2024 to
Dec 2024**, as required under the provision of the Maharashtra Fire Prevention &
Life Safety Measures Act ,2006(Mah-III of 2007). The details of the inspection &
maintenance of installation carried out by me/us are mentioned in the report appended
herewith.

Place : Sangli
License No:-
HYDRANT- MFS-LA/RF-208
DETECTION- MFS-LA/RD-212
PASSIVE PROTECTION - MFS-LA/RP-64



SAFE HOUSE FIRE ENGINEERING SERVICES



SAFE HOUSE FIRE ENGINEERING SERVICES

Maharashtra Fire Services Authorized Company

WE INSTALL AND SUPPLY ALL KINDS OF FIRE EQUIPMENTS

REGISTERED OFFICE : PLOT NO. 17,
ANNA SMRUTI, RAJPUT MALA,
ABHAYNAGAR, SANGLI - 416416.

+91 702 056 1080.
+91 830 875 6131.

CORPORATE OFFICE : SHOP NO. 1, PLOT NO. 27,
SECTOR 22, GANESH HOUSING SOCIETY,
KAMOTHE, NAVI MUMBAI 410209.

safehousefireservices@gmail.com
info@safehousefires.com

BRANCH OFFICE : OPPOSITE SAHYADRI HOTEL,
HADAPSAR-SASWAD ROAD URALI DEVANCHI,
TAL.-HAVELI, DIST-PUNE - 412308.

Web: www.safehousefires.com

REF. NO SHFES/01/13

DATE : 13/ 01/ 2025

TEST CERTIFICATE

[See section 3(3) and rules 4(2)]

Certified that I/We have Carried out inspection Of fire Prevention & Life Safety Measures
Installed In the following Building or Premises namely ,

To,
M/s. Dhanvantri Hospital,
Sant Dynaneshwar Shikshan Sanstan,
Gat No 607/1 & 607/ 3 at. Post Ashta,
Tal - Walwa, Dist - Sangli .

are maintained in good repair and efficient conditions during the period **Jul 2024 to Dec 2024**, as required under the provision of the Maharashtra Fire Prevention & Life Safety Measures Act ,2006(Mah-III of 2007). The details of the inspection & maintenance of installation carried out by me/us are mentioned as below herewith.

Following List Of Material Installed & tested succesfully -

Sr No	Description	Qty	Testing	Remark
1	900 LPM Main Fire Pump	01 Nos	YES	OK
2	Main Fire Pump Panel	174 Mtr	YES	OK
3	100 MM MS Pipe	174 Mtr	YES	OK
4	80 MM MS Pipe	12 Mtr	YES	OK
5	Two Way Inlet Connection	01 Nos	YES	OK
6	Single Headed Hydrant Valve	08 Nos	YES	OK
7	15 Mtr Long Hose Pipe RRL	08 Nos	YES	OK
8	Branch Pipe	08 Nos	YES	OK
9	Single Door Hose Box	08 Nos	YES	OK
10	Swinging Type Hose Reel	07 Nos	YES	OK
11	Single Loop Addressable Fire Alarm Panel	01 Nos	YES	OK
12	Addressable Type Smoke Detector	150 Nos	Yes	Ok
13	Addressable Manual Call Point	06 Nos	Yes	Ok
14	Addressable Hooters	06 Nos	Yes	Ok
15	ABC TYPE FIRE EXTINGUISHER 4 Kg	08 Nos	Yes	Ok
16	CO2 TYPE FIRE EXTINGUISHER 2 Kg	01 Nos	Yes	Ok

Place : Sangli

License No:-

HYDRANT- MFS-LA/RF-208

DETECTION- MFS-LA/RD-212

PASSIVE PROTECTION - MFS-LA/RP-64



SAFE HOUSE FIRE ENGINEERING SERVICES